



MRL Model

Designed to back up power for the existing VVVF-controlled lift system for bringing the lift to the nearest floor and opening the lift door in the event of mains power failure.

Features:

- Enhance passenger safety
- Powered by sealed lead acid battery
- Reliable microprocessor control
- Qusi-sine wave technology
- Window software for remote Monitoring system
- Mostly used in HDB projects
- Simple, time saving for installation and maintenance
- Temperature compensation






ARD1560 MRL series can supply back up power to any kind of existing VVVF-controlled lift system with simple installation; it is powered by sealed lead acid maintenance free batteries.

Technical Specifications:

| Model | 1560-2L-XJP | 1560-3L-XJP |
|---|--------------------------|--------------------------|
| Nominal Battery / Input Voltage | DC 48V | DC 48V |
| Nominal Battery Current | DC 5 - 20A | DC 5 - 40A |
| Battery Capacity | 12V 90W | 12V 90W |
| Output | 3 phase 4 wires | 3 phase 4 wires |
| Output Power | < 2000VA | < 3000VA |
| Output Voltage | 415Vac±5% | 415Vac±5% |
| Output Frequency | 50Hz±1% | 50Hz±1% |
| Output Voltage Waveform | Qusi-Sinusoidal Waveform | Qusi-Sinusoidal Waveform |
| Output Motor Power | 15KW and below | 25KW and below |
| Recommended Motor Speed | <5Hz | <5Hz |
| Battery Charger | | |
| Input Voltage | 240Vac±5% (50Hz±1%) | |
| Charging Current | 3.0A Max | |
| Boost Voltage | 57.60V Max | |
| Nominal Floating Voltage | 53.20V | |
| Temperature Compensation | -75mV/°C | |
| Safety Alarm | | |
| Battery Voltage Low | 42.40V | |
| Over-Heat of Inverter | >65°C temperature rise | |
| Over-load | >120% Rated Output Power | |
| Time Delay for Detecting Mains Power Failure | 0 - 60 Seconds | |
| Self-test and Take-over Time | 10 Seconds | |
| Starting Time for Output Power Limit | 2 Seconds | |
| Emergency Mode Time-out | 4.0 Mins | |
| Dimension (L x W x H) mm | 430 x 230 x 900 | 430 x 230 x 900 |
| Weight (kg) | Approx. 47 w/o battery | Approx. 50 w/o battery |
| Standard | IEC 62040-1 | IEC 62040-1 |



Block 3027A Ubi Road 3 #01-93, Singapore 408656

Tel No: (65) 68485980

e mail: alfred_tankk@singnet.com.sg

web site: www.dce.com.sg